

ALTONA RURAL WATER SERVICES COOP LTD.
PUBLIC WATER SYSTEM ANNUAL REPORT

-2021-

Name of the Public Water System: Altona Rural Water Services Coop Ltd.

Name of the Legal Owner: Altona Rural Water Services Coop Ltd.

Contact Person : Rudy Martens

Phone: 204-324 -7658

E-Mail: remartens555@gmail.com

Water System's Emergency Number: 204-324-4082 Ronn Smith

Name of Operator: Howard Wiebe

Emergency Number: 204-324-1572 **E-mail:** howardlwiebe@gmail.com

Date prepared February 10, 2022

Table of Contents

Introduction: _____	3
1. Description of the Water System: _____	3
1.1 Water Supply Source: _____	3
1.2 Water Treatment Process: _____	3
1.3 Distribution System: _____	3
1.4 Storage Reservoir: _____	3
Treated Reservoir Capacity (400,000) Liters: _____	3
1.5 Number of Connections, Population served and types of Water Users: _____	3
1.6 Classification and Certification: _____	3
2. Disinfection System in Use: _____	4
2.1 Type of Disinfection System used: _____	4
2.2 Equipment Redundancy and Monitoring/ Reporting: _____	4
3. List of Water Quality Standards: _____	4
3.1 Disinfectant Residual Monitoring/ Reporting: _____	4
3.2 Bacteriological Monitoring/ Reporting: _____	4
3.3 Disinfection Byproducts Monitoring/ Reporting: _____	4
4. Water Systems Failures and Corrective Actions: _____	4
5. Drinking Water Safety Orders on your System and Actions taken in response: _____	4
6. Boil Water Advisories Issued and Actions taken in response: _____	4
7. Warnings Issued or Charges laid on the System in Accordance with the Drinking Water Safety Act: _____	4
8. Major Expenses Occurred: _____	5
9. Future System Expansion and or Increased Production: _____	5

Introduction:

The 2021 Annual Report for the Altona Rural Water Services Coop Ltd. summarizes the Water Utility’s ability to provide Safe Potable Drinking Water and meet Provincial Regulations.

1. Description of the Water System:

The Altona Rural Water Services Coop Ltd. Water System provides safe potable drinking water to a population of approximately 1200 residents.

1.1 Water Supply Source:

The Altona Rural Water Services Coop Ltd. purchases and receives all of its water from the Pembina Valley Water Cooperative. The source of the water for the Altona Rural Water Cooperative is the Red River.

1.2 Water Treatment Process:

The water is treated by the Pembina Valley Water Cooperative and re-chlorinated upon entering the water storage reservoirs in Altona and Horndean.

1.3 Distribution System:

Treated water from the reservoirs is pumped throughout the Altona Rural Water Service’s distribution system via 2 - 7.5 submersible pumps located in the Altona reservoir and 1 pump in the Horndean reservoir. The distribution system is approximately 112 miles in length and is comprised 100% PVC piping.

1.4 Storage Reservoirs:

Name: Treated Water Reservoir (Altona)	Capacity: 583,000 liters
Treated Water Reservoir (Horndean)	Capacity: 225,000 liters

1.5 Number of Connections, Population served and types of Water Users:

The Altona Rural Water Services Coop Ltd. is comprised of 434 service connections. All service connections are metered; and serve residential households for approximately 1200 people.

1.6 Classification and Certification:

Operating License for a Public Water System. License # PWS-08-188-02.
Effective July 1, 2017 Expiry Date of November 30, 2022.
Operators are certified under the Environment Act’s Water and Waste-water Facility Operators Regulation.

Certification Level of Operators:

Howard Wiebe:	Water Distribution Class 1
	Water Treatment Class 1
Frank Braun:	Water Distribution Class 1

2. Disinfection System in Use:

2.1 Treated water is re-chlorinated as it enters the water storage reservoirs at Altona and Horndean with the use of 12% Sodium hypochlorite solution, fed into the incoming water via a chemical feed pump.

2.2 As required by the Drinking Water Safety Act, the Altona Rural Water Services Coop Ltd. ensures continuous re-chlorination is maintained at both reservoirs. A spare chemical pump is kept on hand at the reservoir as well as necessary spare parts.

Chlorine residuals are monitored daily at both reservoirs and bi-weekly in the distribution system bacteriological samples are taken. Free and total chlorine residuals are recorded and sent to the Office of Drinking Water at the end of each month.

3. List of Water Quality Standards:

-The Altona Rural Water Services Coop Ltd. does not have a detailed Chemistry Analysis.

3.1 Disinfectant Residual overall performance/results

	Regulatory Requirements	Altona PWS Performance	Horndean
A. Free Chlorine Residual entering the Distribution	>0.5mg/L	100%	100%
B. Frequency of Testing entering the Distribution System	Daily	100%	100%
C. Free Chlorine Residual in the Distribution System	> 0.1 mg/L	100%	100%
D. Frequency of testing in the Distribution System	Bi-weekly	100%	100%
E. Report Submissions	Monthly	100%	100%

3.2 Bacteriological Monitoring and Reporting

A. Frequency of Testing	Bi-weekly	100%	100%
B. Total coliforms present in samples	0 TC per 100ml	100%	100%
C. Escherichia coli present in Samples	0 TC per 100ml	100%	100%

3.3 Disinfection Byproducts Monitoring and Reporting

A. Trihalomethane Sampling Requirements	Quarterly
B. Total Trihalomethane Standard	<0.100 mg/L (average of quarterly samples)
C. Haloacetic Acid Sampling Requirements	Quarterly
D. Total Haloacetic Acid Standard	<0.080 mg/L (average of quarterly samples)

4. Water Systems Failures and Corrective Action

In 2021 No Treatment Barrier for Trihalomethanes (THM), Water system was compliant in the audited time period.

5. Drinking Water Safety Orders on your System and Actions taken in response:

In 2021 no Drinking Water Safety Orders were issued for the Altona Rural Water Services Coop.

6. Boil Water Advisories Issued and Actions taken in response:

In 2021 no Boil Water Advisories were issued

7. Warning issued or Charges laid on the System in accordance with the Drinking Water Safety Act:

In 2021 no Warnings were issued nor charges laid on the Altona Rural Water Services Coop

8. Major Expenses Occurred:

9. Future System expansion and or Increased Production:

No Expansion or Increases in Production are expected.

Line #	Community Code	TC	EC	HPC	Collection Date	Location
1	4.50	0	0		2021-01-04	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
2	4.50	0	0		2021-01-04	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
3	4.50	0	0		2021-01-04	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
4	4.50	0	0		2021-01-04	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
5	4.50	0	0		2021-01-19	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
6	4.50	0	0		2021-01-19	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
7	4.50	0	0		2021-01-19	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
8	4.50	0	0		2021-01-19	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
9	4.50	0	0		2021-02-01	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
10	4.50	0	0		2021-02-01	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
11	4.50	0	0		2021-02-01	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
12	4.50	0	0		2021-02-01	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
13	4.50	0	0		2021-02-15	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
14	4.50	0	0		2021-02-15	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
15	4.50	0	0		2021-02-15	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
16	4.50	0	0		2021-02-15	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
17	4.50	0	0		2021-03-01	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
18	4.50	0	0		2021-03-01	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
19	4.50	0	0		2021-03-01	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
20	4.50	0	0		2021-03-01	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
21	4.50	0	0		2021-03-15	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
22	4.50	0	0		2021-03-15	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
23	4.50	0	0		2021-03-15	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
24	4.50	0	0		2021-03-15	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
25	4.50	Absent	Absent		2021-03-29	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
26	4.50	0	0		2021-03-29	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
27	4.50	Absent	Absent		2021-03-29	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
28	4.50	0	0		2021-03-29	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
29	4.50	0	0		2021-04-12	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
30	4.50	0	0		2021-04-12	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
31	4.50	0	0		2021-04-12	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
32	4.50	0	0		2021-04-12	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
33	4.50	0	0		2021-04-26	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS

102	4.50	0	0		2021-12-29	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
103	4.50	0	0		2021-12-29	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS
104	4.50	0	0		2021-12-29	ALTONA RURAL WATER CO-OP (RED RIVER REGIONAL) - PWS

Line #	Sample Type	Sample ID	Sample Number
1	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA RES OUT	L2545399-1
2	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA @ _____	L2545399-2
3	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN RES OUT	L2545399-3
4	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN @ _____	L2545399-4
5	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA RES OUT	L2550040-1
6	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA @ 71N KLASSEN	L2550040-2
7	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN RES OUT	L2550040-3
8	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN @ SUSANNA MALU	L2550040-4
9	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA RES OUT	L2553827-1
10	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA @ LE	L2553827-2
11	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN RES OUT	L2553827-3
12	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN @ RF	L2553827-4
13	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA RES OUT	L2557794-1
14	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA @ LE	L2557794-2
15	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN RES OUT	L2557794-3
16	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN @ SS	L2557794-4
17	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA RES OUT	L2562745-1
18	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA @ _____	L2562745-2
19	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN RES OUT	L2562745-3
20	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN @ _____	L2562745-4
21	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA RES OUT	L2567384-1
22	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA @ LE	L2567384-2
23	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN RES OUT	L2567384-3
24	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN @ J.K	L2567384-4
25	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA RES OUT	L2572241-1
26	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA @ _____	L2572241-2
27	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN RES OUT	L2572241-3
28	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN @ _____	L2572241-4
29	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA RES OUT	L2575958-1
30	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA @ LZ	L2575958-2
31	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN RES OUT	L2575958-3
32	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN @ RF	L2575958-4
33	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA RES OUT	L2580910-1

34	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA @ _____	L2580910-2
35	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN RES OUT	L2580910-3
36	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN @ _____	L2580910-4
37	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA RES OUT	L2586428-1
38	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA @ H.NEATS	L2586428-2
39	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN RES OUT	L2586428-3
40	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN @ L.ENNS	L2586428-4
41	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA RES OUT	L2591781-1
42	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORDEAN @	L2591781-2
43	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN RES OUT	L2591781-3
44	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA @ _____	L2591781-4
45	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA RES OUT	L2599717-1
46	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN	L2599717-2
47	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN RES OUT	L2599717-3
48	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA	L2599717-4
49	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA RES OUT	L2605862-1
50	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORDEAN @	L2605862-2
51	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN RES OUT	L2605862-3
52	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA @	L2605862-4
53	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA RES OUT	L2610223-1
54	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN	L2610223-2
55	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN RES OUT	L2610223-3
56	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA	L2610223-4
57	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA RES OUT	L2617390-1
58	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN @ RODNEY FUNK	L2617390-2
59	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN RES OUT	L2617390-3
60	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA @ LEN ENNS	L2617390-4
61	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA RES OUT	L2622888-1
62	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA @ J.S.	L2622888-2
63	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN RES OUT	L2622888-3
64	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN @ BUFFALO MILLS	L2622888-4
65	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA RES OUT	L2629131-1
66	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA @ L. ENNS	L2629131-2
67	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN RES OUT	L2629131-3

68	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN @ R. FUNK	L2629131-4
69	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA RES OUT	L2635070-1
70	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN @ J.S.	L2635070-2
71	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN RES OUT	L2635070-3
72	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA @ L.E.	L2635070-4
73	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA RES OUT	L2640436-1
74	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN @ HEARTLAND MEA	L2640436-2
75	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN RES OUT	L2640436-3
76	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA @ L.E.	L2640436-4
77	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA RES OUT	L2646351-1
78	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN @ R. F	L2646351-2
79	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN RES OUT	L2646351-3
80	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA @ L. E	L2646351-4
81	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA RES OUT	L2651245-1
82	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN @ J.S.	L2651245-2
83	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN RES OUT	L2651245-3
84	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA @ L.E.	L2651245-4
85	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA RES OUT	L2656758-1
86	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA @ _____	L2656758-2
87	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN RES OUT	L2656758-3
88	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN @ _____	L2656758-4
89	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA RES OUT	L2664138-1
90	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA @ LE	L2664138-2
91	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN RES OUT	L2664138-3
92	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN @ RF	L2664138-4
93	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA RES OUT	L2669306-1
94	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN @ J.S	L2669306-2
95	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN RES OUT	L2669306-3
96	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA @ L.E	L2669306-4
97	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA RES OUT	L2673312-1
98	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA @ _____	L2673312-2
99	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN RES OUT	L2673312-3
100	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN @ _____	L2673312-4
101	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA RES OUT	L2676101-1

102	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - ALTONA @ R.F.	L2676101-2
103	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN RES OUT	L2676101-3
104	DRINKING WATER - DISTRIBUTION	ALTONA RWC 3 - DIST - HORNDEAN @ L.E.	L2676101-4